



Loviisa spent fuel storage risk analysis

PSAM16 / 26.6.-1.7.2022 / Jukka Koskenranta (Seismic), Ilkka Paavola (Internal events), Rasmus Hotakainen (HRA), Taisto Laato (Level 2)

Join the
change

fortum

Introduction




Loviisa Nuclear Power Plant

- Located in southern Finland
- 2 x 500 MWe VVER-440 units (1977/1980)
- Current operating license until 2027/2030
 - Extension applied for 2050 for both units

Loviisa PRA

- Since early 1990's
- Includes
 - Level 1 and 2 PRA
 - Reactor, refueling pool, spent fuel storage
 - All operating and shutdown states
 - All types of initiating events
- Updated annually
- Significant upgrades to reduce risks
- Main source of initiating events for spent fuel storage risk analysis

Loviisa 1 Risk distribution



Loviisa spent fuel storage PRA

- Details and background of Loviisa NPP SFS
- Loviisa SFS PRA analysis 2030 (2018, revised in 2021)
 - General scope
 - Results
 - Seismic initiating events
 - Need of further development

Loviisa spent fuel storage (SFS)

- Loviisa NPP spent fuel cycle:
 - 1. Refueling pool in reactor building 1 – 2 years
 - **2. Water pools in spent fuel storage 10 years – many decades**
 - 3. Final repository at Olkiluoto – First in the world, starting in few years
 - History of Loviisa NPP SFS
 - About first 10 - 15 years of Loviisa NPP operation spent fuel was sent to Russia
 - After regulation changed Loviisa NPP needed to store more spent fuel at the site and expand the original SFS
 - Two units in two buildings
 - SFS1 is original SFS: Build with same criteria as storage pools in reactor building
 - SFS2 has been build in two stages: 1981 ... 1984 and 1996 ... 1999
 - New upgrades or changes needed if Loviisa NPP continues operation after current license 2030
- Differences need to be taken into account in SFS PRA

SFS PRA General scope

Repair Consideration

- Recovery failure probabilities are calculated by formula $\text{EXP}(-T_2/T_1)$
 - First row: Average time needed to recover (T_1)
 - Mainly based on engineering judgements
 - First column: Average time available to recover (T_2)
 - Based on heating power at maximum capacity of current license 2030
- Minimum value for recovery failure probability is 1E-6

Time windows/mission time

- From No time to recover
 - building collapse
- To 1 month (SFS1) or 2 month (SFS2)
 - stop of spent fuel pool cooling

		Time needed T_1						
		3 h	6 h	12 h	24 h	2 d	4 d	8 d
Time available T_2	1,5 h	6.1E-01	7.8E-01	8.8E-01	9.4E-01	9.7E-01	9.8E-01	9.9E-01
	3 h	3.7E-01	6.1E-01	7.8E-01	8.8E-01	9.4E-01	9.7E-01	9.8E-01
	6 h	1.4E-01	3.7E-01	6.1E-01	7.8E-01	8.8E-01	9.4E-01	9.7E-01
	12 h	1.8E-02	1.4E-01	3.7E-01	6.1E-01	7.8E-01	8.8E-01	9.4E-01
	24 h	3.4E-04	1.8E-02	1.4E-01	3.7E-01	6.1E-01	7.8E-01	8.8E-01
	2 d	1E-06	3.4E-04	1.8E-02	1.4E-01	3.7E-01	6.1E-01	7.8E-01
	4 d	1E-06	1E-06	3.4E-04	1.8E-02	1.4E-01	3.7E-01	6.1E-01
	8 d	1E-06	1E-06	1E-06	3.4E-04	1.8E-02	1.4E-01	3.7E-01
	16 d	1E-06	1E-06	1E-06	1E-06	3.4E-04	1.8E-02	1.4E-01
	32 d	1E-06	1E-06	1E-06	1E-06	1E-06	3.4E-04	1.8E-02
	64 d	1E-06	1E-06	1E-06	1E-06	1E-06	1E-06	3.4E-04
	128 d	1E-06	1E-06	1E-06	1E-06	1E-06	1E-06	1E-06

SFS PRA General scope

Success Criteria & End States

- Spent fuel rods are submerged
- Residual heat is removed by normal cooling system or by boiling and pool refilling
 - Both are considered acceptable end states
 - Lots of time to recover normal cooling system

Criteria for results evaluation

- Fuel exposure or mechanical damage


Level 2 considerations

- Fuel damage is also large release
 - No containment around SFS

Spent fuel storage 1&2 PRA 2030 Analysis updated 02/2021

- SFS 1&2 Fuel damage frequency (FDF) $1,9E-7/a$
 - 1 % of Lo1&2 Σ CDF
- SFS 1&2 Large release frequency (LRF) $1,9E-7/a$
 - 2 % of Lo1&2 Σ LRF
- **SFS 1&2 Early release frequency (ERF) $5,2E-8/a$**
 - **28 % SFS FDF**
 - **10 % of Lo1&2 Σ ERF**

IEQ_SFS_RACK	SFS pool steel liner leak due to fuel rack movement and pool concrete structure crack due to EQ
ISFS_DRAIN_UH	SFS pool erroneous drainage due to operator error
ISFS_COOLSTOP	All SFS TG-cooling stop initiators (plant data)
IEQ_SFS_BUILDING	SFS building collapse due to EQ
ISFS_COOLSTOP_LR	SFS TG-cooling stop due to reactor CD and large release
ISFS_LINER	SFS pool liner leakage (plant data)
ISFS_WIND53	High wind speed (>53 m/s)
IEQ_SFS_LINER	SFS pool liner and concrete structure leakage due to EQ



Seismic initiating events

- Seismic initiating events cause 58 % of the total spent fuel storage fuel damage frequency
- Seismic initiating events like pool rupture or building collapse do not benefit low heating rate of the SFS like most of the other initiating events
- Most significant initiating event is fuel rack moving because of earthquake
 - Fuel rack rips steel liner while moving, earthquake cracks water leakages to concrete structures of the pool
 - Initiating event share from the total spent fuel storage fuel damage frequency is 53 %
- Collapse of the building because of seismic initiating event: 5,3 % of the total FDF
- Also some other seismic initiating events, mainly screened out or included in other events

Spent fuel storage 1&2 PRA 2030 (updated 02/2021)

Need of further development

- Most development needs are related to seismic initiating events
- SFS PRA is based on 2018 seismic hazard
- Seismic hazard was updated already late 2021 and it is slightly higher
 - SFS PRA will be updated to consider the new seismic hazard
 - SFS risks estimate increasing because of the seismic hazard update
- Loviisa NPP SFS has been built in three stages
 - Only some of the variations have been seismically evaluated: $\frac{3}{4}$ fuel racks, $\frac{1}{2}$ buildings
 - Modelled with lowest known seismic capacities
- Uncertainties in SFS analysis are significant
- Absolute uncertainties are small compared to absolute uncertainties in reactor risk analysis

Thanks!

Questions?