



ÚJV Řež, a. s., Czech Republic  
**PSA Applications for  
Dukovany NPP**  
Stanislav Hušťák



# Presentation Outline

---



- **Overview of Living PSA project for Dukovany NPP**
- **Regulatory Decrees and guides for PSA applications**
- **Performed PSA applications for Dukovany NPP**
- **Main outputs**
- **Main insights and conclusions**

# PSA for Dukovany NPP



## ■ Dukovany NPP

- VVER-440/213 type plant in the Czech Republic
- four almost identical units, 500 MWe each

## ■ Living PSA Project

- developed and maintained in ÚJV Řež, a. s., for Dukovany NPP
  - RiskSpectrum<sup>®</sup> PSA software
- basis for PSA applications at Dukovany NPP
  - evaluation of Technical Specifications (TS)
  - selection of important components
  - risk monitoring (the most extensive one, Safety Monitor<sup>™</sup> is utilized)
  - analysis of occurred events, analysis of modifications etc.
- the first two applications are subject of this presentation

## ■ Full-scope Level 1 & Level 2 PSA

- all plant operating modes
- internal initiating events (IEs), internal and external hazards,
- risk from reactor core as well as from spent fuel pool (SFP)
  - Core Damage Frequency (CDF)
  - Fuel Damage Frequency (FDF) = CDF + frequency of fuel damage in SFP

## ■ Fully integrated PSA model

- all plant operating states (POSSs) and IEs are modeled in the same PSA project
  - no separate PSAs for shutdown operation, hazards or SFP risk

# Regulatory Decrees and Guidelines



## ■ Czech implementing Decree 162/2017

- requires to use PSA applications for the selected purposes

## ■ Czech regulatory safety guides

- support some PSA applications incl. those required by Decree
- BN-JB-2.5 (analogous to IAEA SSG-3)
  - supports PSA applications generally
- BN-JB-2.6 (analogous to US NRC RG 1.174)
  - supports RIDM for changes initiated by plant
- BN-JB-2.7 (analogous to US NRC RG 1.177)
  - supports TS evaluation
- BN-JB-2.8 (analogous to NEI-00-04)
  - supports PSA based selection of important components

# Evaluation of Technical Specifications



## ■ Implementing Decree 162/2017

- it requires to assess both the need for TS modifications and acceptability of TS changes initiated by plant

## ■ Regulatory safety guide BN-JB-2.7

- supports TS changes initiated by plant as well as AOT adequacy
  - incremental conditional core damage probability (ICCDP)  $\leq 5 \times 10^{-7}$
  - incremental cond. large early release probability (ICLERP)  $\leq 5 \times 10^{-8}$
  - acceptable yearly risk increase is defined in BN-JB-2.6 (not applicable for evaluation of AOT adequacy since it is not related to change)
- guideline and discussion for comparison of alternatives
  - when plant would choose this option to justify TS change
  - approximately the same level of conservatism should be applied in models for compared alternatives

# Evaluation of Technical Specifications



## ■ TS evaluation performed recently for Dukovany NPP

### ■ main objectives

- identification of the eventual need for TS modification
- identification of potential for AOT extension
- comparison of alternatives for the cases selected by plant

### ■ scope of evaluation

- more than 250 cases for various combinations of limiting conditions for operation (LCOs) and AOTs
- diverse and mobile (DAM) requirements for availability were included
- risk associated with AOT in Mode 1 was assessed, several evaluations were done also for other Modes
- unit No. 1 was selected as a representative one
- internal and external hazards were included in calculation of AOT risk

# Evaluation of Technical Specifications



## ■ Main features

- entry into LCO selected for calculation
  - identified most unfavorable case of entry into each LCO
  - limited to single failure or single common cause failure (CCF)
  - conditioning of CCF was applied when components redundant to failed one are not subsequently tested (if CCF is credited in PSA)
- calculation of risk associated with AOT
  - such risk was compared with criteria for ICCDP and ICLERP
  - determination of maximal AOT for given LCO, it allows plant to identify potential proper candidates for AOT extension
- RiskSpectrum PSA software was used for calculations



# Evaluation of Technical Specifications



## ■ Main outputs

- all evaluated LCOs have been found adequate
- a few exceptions were identified
  - some cases of motor operated valve (MOV) unavailability when CCF conditioning was applicable
- TS modifications for Dukovany NPP were proposed
  - mainly to decrease risk associated with AOT for several cases of MOV unavailability
  - they include new TS requirements to test MOVs in the other redundant divisions when one of the redundant MOVs fails
  - sensitivity analyses to show benefit of modifications were performed
- finally, plant made several changes in TS based on these proposals

# Evaluation of Technical Specifications



## ■ Comparison of alternatives



- the following alternatives were compared for selected cases
  - risk from continuation at power with unavailable component
  - vs. risk from shutdown after AOT expires
  - for the same time period
- main insights
  - continuation at power operation has not been found to be better option in the analyzed cases
  - output of comparison is often highly dependent on expected time to repair, duration of transition states, etc.
  - output of comparison was not often decidable, e.g. when output based on CCDP comparison gave results different from output based on CLERP comparison for the same component unavailability

# Comparison of Alternatives



## ■ Unavailability of essential service water (ESW) division

■ CCDP and CLERP dependent on time to repair (TR) is shown



— continuation of operation in Mode 1; — shutdown after AOT expires

Note: Risk from time interval corresponding to startup in shutdown case (just after repair is completed) is added at the beginning of calculation for both alternatives

# Selection of Important Components



## ■ Regulatory Decree 162/2017

- requires to identify components with impact on plant safety using PSA for various purposes

## ■ Regulatory safety guide BN-JB-2.8

- support for PSA based selection of important components
  - regardless of the purpose (it is not specified here)
  - importance measures are utilized to assess (non-negligible) impact
- important component
  - FV (Fussell-Vesely) for sum of component failure modes  $\geq 0.005$
  - the highest Risk Achievement Worth (RAW)  $\geq 2$  (including CCF)
  - either in FDF calculation or in LERF calculation
  - either for internal IEs (incl. internal hazards) or for external IEs

# Selection of Important Components



## ■ Performed for components at Dukovany NPP

- both for plant and for regulator
- PSA based using importance measures
- integrated PSA model was used
  - importance measures were not determined separately for shutdown states nor for internal hazards

## ■ List of important components based on PSA

- mostly safety or safety-related components
- some non-safety components
  - added to plant list of „non-categorized equipment with impact“ for graded treatment

# Main Insights and Conclusion



## ■ Living PSA project for Dukovany NPP

- effective tool to control and reduce plant risk level
  - in accordance with requirements of Regulatory Decree
  - especially, PSA is used to propose measures at plant if necessary
  - evaluation of TS adequacy to identify the need for TS changes contributes to this PSA objective as well
- provides support for risk informed decision making at Dukovany NPP
  - for changes initiated by plant
  - it includes also identification of potential for such kind of changes
- provides support for site inspectors of Czech regulator as well
  - list of important components based on PSA importance measures is used as a support to determine significance of issues and findings



---

# Thank you for your attention